

Test Report Chemical - Admixture

Name of Client :- J.Kumar Infra Projects Ltd	Date of Issue :- 17.11.2016
Office Address :- 16-A,Andheri Industrial Estate,Veera Desai Road, Andheri (W),Mumbai-400058,India	Sample Ref. No. :-BSAPL/Chem/004/1
Project Address :- DMRC/MU/Dahisar to DN Nagar Part Design & Construction of Viduct	Date of Receipt :- 09.11.2016
Contact person :- Mr.Sunder Rajan	Date of Testing :- 14.11.2016 To 15.11.2016
Name of Contractor :- J.Kumar -CRTG(JV)	Report No. :-BSAPL/Chem/004/1
Consultant Ref.No. :- JKCRTGJV/DMRC-OTHERS/LINE2/2016-17/176 ,Date:-08.11.2016	
Sample Description :- Biopolar Admixture AT-ANTICOR BP,Batch no.AT/PL/753	
Source of Sample :- Supplied by Customer	
Condition of sample :- Good	

A) Chemical Analysis:--

Sr.No	Test Parameter	Unit	Results	Method used
1	Appearance	-	Brownish colour Liquid	-
2	Odour	-	Ammonical	-
3	pH	-	10.87	-
4	Density @ 27°C	-	1.050	IS 1448 : 1990
5	Viscosity @ 27°C	sec	11 sec	IS 101:1989

Notes:

- 1) Any test report shall not be reproduced except in full, without the written permission from BSAPL.
- 2) Any correction invalidates this certificate.
- 3) The Test Report and Results relate only to the sample tested.
- 4)* indicates this value not cover under NABL approved range of testing/Limit of detection.

Authorized signatory

Sanjay Patil
Sanjay Patil
Technical Manager

