

TEST REPORT

ADOADDITIVES TECHNOLOGIES PVT.LTD.
D-1,ACHARYA NIKETAN
MAYUR VIHAR,PHASE-1
DELHI-110091, DELHI
INDIA

Phone/Fax:
Kind Attn.: MR VINAY UPADHYAY

Report No.: 161220078-1

Date: 24-Dec-2016

Sample Description :

DOR: 20-Dec-2016

ADMIXTURE AT-NIT(L) BATCH NO-AT/PL/764 OF M/S GULERMAK-TPL JV LUC
KNOW METRO RAIL PROJECTS-LKCC-06,LUCKNOW

Your Ref. No. :

ID No - 161220078-1

Date of Start of testing:- 20.12.2016

Date of Completion of testing:- 24.12.2016

Admixture AT-NIT (L)
As per table 2 of IS: 9103-1999

S.No.	Test Parameters	Observed Value	Test Method
1.	Appearance	Grayish Viscous liquid	Visual observation
2.	Initial Setting , min	2.5 min	IS:4031-1989 Part 5 Guidelines
3.	Relative density	1.34	IS:9103-1999/Annex-E
4.	Chloride as Cl, % by mass	0.06	IS:9103-1999/Annex-E
5.	pH value at 25 ^o c	10.16	IS:9103-1999/Annex-E

----- END OF TEST REPORT -----


Analyst

CCREQD\1\RA000\A16100




P.K. TIWARI
MANAGER
B.M. LAB
Authorized Signatory

TRA - 266459